



cfo-jmc@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOJMC/2021/00001579
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOJMC/2021/00001579/R2

Date: 12/06/2026

Building Occupancy/Category: Educational (non-residential)

To,

VIJAYA FIRE ENGINEERING WORKS
P.N MARG P.N MARG JAMNAGAR Jamnagar MC 361001
Fire Region: Jamnagar MC
Mobile No: 9328108012 Email ID: vijayafireengineeringworks@gmail.com

We have received Application No. 2026/00189319 dated 02/06/2026 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise ST FRANCIS SCHOOL (name of the Building/Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: JAMNAGAR
5. Name of Block(s): ST FRANCIS SCHOOL

The building/premise was inspected on 12/06/2026 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 12/06/2026
2. Six monthly inspection was done on 12/06/2026

The Fire Safety Certificate is renewed for a period of **two (2)** years upto 12/06/2028 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated:



Digitally Verified

Digitally verified by: Mukesh Ganesh Vasu
Fire Safety Officer - Specialist (FSO-S)
2021/000676
#Error
Date: 12/06/2026
Time: 08:08 PM



FSCA/O/CFOJMC/2021/00001579/R2

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetypcop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and drill to be conducted every six months. If there is a delay in scheduled inspection or mock drill, the certificate should be renewed after two years to avoid penalties.